

## Maintenance Aqualift F Compact



### Article information

Item no.: 80302

GTIN:

Price group: 00

### Description

Maintenance of the lifting station Aqualift F Compact

#### Scope of services (all work is carried out according to the inspection card):

- Visual inspection to make sure that it is functioning
- Cleaning the system
- Checking the non-return valves
- Checking the pump function
- Checking the control unit
- Information on the maintenance obligation for the owner-operator, optional
- System must be handed over in a safe operational state
- The recorded values are documented in a maintenance report

#### Requirements on site:

- Contact person must be on site
- Access to the system and control unit
- A hose water connection must be provided nearby

#### Note:

- Regular maintenance is a prerequisite for the warranty and insurance cover
- 

#### Not included are costs for:

- Material expenses over 20 euros
- Any additional incidental expenses are charged based on the expenses incurred
- Difficult conditions, repair services, additional work
- Wasted journeys despite prior notice

Lifting station must be regularly serviced by a specialist company in accordance with EN 12056-4.

**The following intervals must not be exceeded:**

- 3 months for systems in commercial use
- 6 months for systems in multi-family homes
- 1 year for systems in single-family homes

The price stated is for each maintenance operation.